Foxboro Elelemtary (Pump Room)

Write down the number for pressure and temp, not just an "X"

| If you need to call in a job sheet, make sure you write down the work order # on this report. | | | | | | |
|---|----------|--|--|--|--|--|
| 1 | 17 | | | | | |
| 2 | 18 | | | | | |
| 3 | 19 | | | | | |
| 4 | 20 | | | | | |
| 5 | 21 | | | | | |
| 6 | 22 | | | | | |
| 7 | 23 | | | | | |
| 8 | 24 | | | | | |
| 9 | 25 | | | | | |
| 10 | 26 | | | | | |
| 11 | 27 | | | | | |
| 12 | 28 | | | | | |
| 13 | 29 | | | | | |
| 14 | 30 | | | | | |
| 15 | 31 | | | | | |
| 16 | indicate | Post this report in the pump room & write your findings daily or as indicated. At the end of the month, share with your principal & email to dsdcustodial@dsdmail.net or fax to 27881. | | | | |
| Fach individual numn requires a senarate report throughout the year | | | | | | |

Each individual pump requires a separate report throughout the year.

The Pump Room is <u>NOT</u> to be used for storage. Keep <u>ALL COMBUSTIBLE MATERIAL OUT</u> of the room!

Nightly Lock-Up: Ensure the pump is on prior to locking up for the night.

| Pump# | ŧ |
|-------|---|
| | |

Pump Room Inspection Report

| School_ | Foxboro | El |
|---------|---------|----|
| | | |

| Month/Year | |
|-----------------|--|
| iviolitii/ real | |

Pump Room

| | | 1st week | 2nd week | 3rd week | 4th week | |
|---|---|-----------------------------|----------|-----------------------|----------|--|
| 1 | Check & test filter indicator lights | | | | | |
| 2 | Replace filters as needed | | | | | |
| | a) Check air compressor oil | | | | | |
| 3 | b) Drain water from tank. (more often if needed) | | | | | |
| 4 | Check pumps for bearing noise, leaking seals & correct pressure | | | | | |
| 5 | Check domestic hot water pumps for broken couplers, motor mounts or leaks | | | | | |
| 6 | Sweep floor, dust equipment & piping (if not asbestos) | | | | | |
| | Every Month | | | | | |
| 1 | Oil domestic hot water pumps & motors | | | | | |
| 2 | Check ERV unit filters & belts. Replace as needed | | | | | |
| 3 | Check for leaks on heating equipment & associated piping | | | | | |
| 4 | Check digital reading on water heater for error codes & temps. In excess of 135. Report any problems/concerns | | | | | |
| 5 | Check emergency lights in bldg. | | | | | |
| 6 | Check generator radiator-fluid level | | | | | |
| 7 | Check generator engine-oil level | | | | | |
| 8 | Log hour meter to verify unit has exercised since last month | Beginning of month reading: | | End of month reading: | | |
| | Every Other Month | | | | | |
| 1 | Pour 1 gallon of water in floor drains | | | | | |
| | Concern/issues regarding your pump(s) & room: | | | | | |